## Total Counter/Time Counter (DIN 72 x 36)

# H7HP

## Compact Total Counters and Time Counters with Easy-to-read Displays and IP66G/ NEMA4 Water and Oil Resistance

- Large, easy-to-read displays: 15-mm-high characters for 6-digit models; 12-mm-high characters for 8-digit models.
- High-visibility, negative transmissive LCD display with built-in red LED backlight at low power consumption.
- Compact (66 mm) body.
- Switch 6-digit models between total counter and time counter operation.





## **Model Number Structure**

### **■** Model Number Legend

**H7HP-**1 2 3 4

1. Classification

A: Total counter/time counter

C: Total counter

2. Digits

None: 6 digits 8: 8 digits 3. Supply Voltage

None: 100 to 240 VAC D: 12 to 24 VDC

4. Case Color

None: Light gray (Munsell 5Y7/1)

B: Black

## **Ordering Information**

#### **■** List of Models

Supply voltage	6-digit total counter/time counter		8-digit total counter	
	Light gray	Black	Light gray	Black
100 to 240 VAC	H7HP-A	H7HP-AB	H7HP-C8	H7HP-C8B
12 to 24 VDC	H7HP-AD	H7HP-ADB	H7HP-C8D	H7HP-C8DB

## **Specifications**

## **■** Ratings

Item		6-digit total counter/time counter		8-digit total counter		
		H7HP-A	H7HP-AD	H7HP-C8	H7HP-C8D	
Rated suppl	ly voltage	100 to 240 VAC (50/60 Hz)	12 to 24 VDC (see note 1)	100 to 240 VAC (50/60 Hz)	12 to 24 VDC (see note 1)	
External por	wer supply	50 mA at 12 VDC		50 mA at 12 VDC		
Operating v	oltage range	85% to 110% of rated supp	85% to 110% of rated supply voltage			
Power cons	Power consumption         100 to 240 VAC: 6.5 VA max.           12 to 24 VDC: 0.6 W max.					
<b>Dimensions</b> 72 x 36 x 66 mm (W x H x D)						
Mounting m	ethod	Flush mounting				
External cor	nnections	Screw terminals				
Degree of p	rotection	1	EM standard IP66G) and NE	,		
Display		7-segment, negative transm	nissive LCD (with red backlig	ıht)		
Digits		6 digits (15-mm-high charac	-	8 digits (12-mm-high charac	cters)	
Function		Total counter/time counter (	<u>'</u>	Total counter		
Input mode	mode Up/down (individual) (total counter), or accumulative (time counter) Up/down (individual)					
Max. counti	ng speeds	30 Hz or 5 kHz (selected via	a DIP switch)			
Counting ra		-99999 to 999999		-9999999 to 99999999		
Time specification		0.1 to 99999.9 h/1 s to 99 h 59 min 59 s				
Timing accuracy		±100 ppm (-10°C to 55°C)				
Memory backup		EEP-ROM: 200,000 operations min.				
Input	Input signals	Count 1 (increment), count 2 (decrement), reset, and key protection (see note 2)				
	Input method	· · ·	1 / 0 1	(PNP transistor input) (selec	ted via DIP switch)	
	Count, start, gate, reset	No-voltage input (NPN transistor input) Short-circuit (ON) impedance: $1 \text{ K}\Omega \text{ max}$ . Short-circuit (ON) residual voltage: $2 \text{ VDC max}$ . Open (OFF) impedance: $100 \text{ k}\Omega \text{ min}$ . Voltage input (PNP transistor input) Short-circuit (ON) impedance: $1 \text{ K}\Omega \text{ max}$ . ON voltage: $9 \text{ to } 24 \text{ VDC}$ OFF voltage: $5 \text{ VDC max}$ . Open (OFF) impedance: $100 \text{ k}\Omega \text{ min}$ .				
Key protectionNo-voltage input (NPN transistor input) Short-circuit (ON) impedance: 1 KΩ max. Short-circuit (ON) residual voltage: 0.5 VDC max. Open (OFF) impedance: 100 kΩ min.						
Input re-	Reset	I .	counter: 20 ms or 1 ms (auto	matically switched according	g to counting speed)	
sponse speed	Start	Time counter: 20 ms				
apeeu	Key protection	Approx. 1 s		Approx. 1 s		
Reset syste	m	External and manual resets				

Note: 1. Contains 20% ripple (p-p) max.

<sup>2.</sup> Only a non-voltage input (NPN transistor) is possible for the key protection input. Switching between the NPN and PNP input methods does not affect the key protection input, i.e., a PNP input cannot be used.

## **■** Characteristics

Insulation resistance	100 MΩ min. (at 500 VDC)			
Dielectric strength	2,000 VAC, 50/60 Hz for 1 min between current-carrying terminal and exposed non-current-carrying metal parts (AC model) 1,000 VAC, 50/60 Hz for 1 min between current-carrying terminal and exposed non-current-carrying metal parts (DC model) 2,000 VAC, 50/60 Hz for 1 min between power terminals and control input terminals (AC model) 1,000 VAC, 50/60 Hz for 1 min between power terminals and control input terminals (DC model)			
Impulse withstand voltage	3 kV (between power terminals) (1 kV for 12-to-24-VDC models) 4.5 kV (between current-carrying terminal and exposed non-current-carrying metal parts) (1.5 kV for 12-to-24-VDC models)			
Noise immunity	±1.5 kV (between AC power terminals), ±480 V (between DC power terminals), ±480 V (between input terminals); square-wave noise by noise simulator (pulse width: 100 ns/1 μs, 1-ns rise)			
Static immunity	Display: Malfunction: 8 kV Destruction: 15 kV  DIP switch: Malfunction: 4 kV Destruction: 8 kV			
Vibration resistance	Destruction: 10 to 55 Hz with 0.75-mm single amplitude, four cycles each in three directions (8 minutes per cycle) Malfunction: 10 to 55 Hz with 0.5-mm single amplitude, four cycles each in three directions (8 minutes per cycle)			
Shock resistance	Destruction: 294 m/s <sup>2</sup> each in three directions Malfunction: 196 m/s <sup>2</sup> each in three directions			
Ambient temperature	Operating: -10°C to 55°C (with no icing) Storage: -25°C to 65°C (with no icing)			
Ambient humidity	Operating: 35% to 85%			
EMC	(EMI) Emission Enclosure: Emission AC Mains: (EMS) Immunity ESD:	E61326 EN55011 Grou EN55011 Grou EN61326 EN61000-4-2:		
	Immunity RF-interference: Immunity Conducted Disturbance:		10 V/m (Amplitude-modulated, 80 MHz to 1 GHz) (level 3); 10 V/m (Pulse-modulated, 900 MHz ±5 MHz) (level 3)	
	Immunity Conducted Disturbance: EN61000-4-6: 10 V (0.15 to 80 MHz) (according to EN61000-6-2) Immunity Burst: EN61000-4-4: 2 kV power-line (level 3); 2 kV I/O signal-line (level 4)			
	Immunity Surge:		1 kV line to lines (power and output lines) (level 2); 2 kV line to ground (power and output lines) (level 3)	
	Immunity Voltage Dip/Interruption:		, , ,	
Approved standards	UL508, CSA22.2 No.14, conforms			
Case color	Rear section: Gray smoke; Front section: 5Y7/1 (light gray) or N1.5 (black)			
Weight	Approx. 106 g			

## **Connections**


### **■** Terminal Arrangement

Note: 1. Incremented for count 1 (CP1) inputs; decremented for count 2 (CP2) inputs.


2. Non-contact input is also available.

#### **AC Models**


#### H7HP-A




#### H7HP-C8



#### DC Models H7HP-AD



#### H7HP-C8D



## **Operation**

## **■ DIP Switch Settings**

Switches 1 to 4 are all set to OFF before shipping.



#### H7HP-A/-AD

Pin no.	Item	OFF	ON
1	Function	Total counter	Time counter
2	Counting speed	30 Hz	5 kHz
	Time range	99999.9 h	99 h 59 min 59 s
3	Input mode (note)	NPN	PNP
4	Unused		


#### H7HP-C8/-C8D

Pin no.	Item	OFF	ON
1	Unused		
2	Counting speed	30 Hz	5 kHz
3	Input mode (note)	NPN	PNP
4	Unused		

Note: When the setting has been changed, turned power off and on to continue. The display will show "0" when the power is turned back on.


## **■** Operating Modes

#### **Total Counters**



Note: Display values are shown for a 6-digit model.


#### **Time Counters**



Note: 1. Display values are shown for full scale set to 99999.9 h.

2. Gate input is available only when H7HP-A settings are made.

## **Nomenclature**



(The figure shows the DIP switch label stuck to the rear of the case.)

1. Reset Key

Resets the count value, but will not operate while the keys are protected.

2. Key Protection Indicator

Lit while the keys are protected (Reset Key is disabled.).

3. DIP Switch


Use to change a setting. Refer to DIP Switch Settings for details.

## **Dimensions**

Note: All units are in millimeters unless otherwise indicated.

H7HP-A H7HP-C8






#### **Panel Cutouts**

Panel cutouts are as shown below (according to DIN43700).



- **Note: 1.** The mounting panel thickness should be 1 to 6 mm.
  - **2.** Water resistance will be lost if Counters are mounted side-by-side.

#### With Flush Mounting Bracket




## **Connections (Common)**

### **■ Input Connections**

Note: The undermentioned is common for all H7GP/H7HP models.

#### No-voltage Input (NPN Input Mode)


#### Reset, Count 1, Count 2, Start, and Gate Inputs



#### Reset, Count 1, Count 2, Start, and Gate Inputs Specification

Note: Two-wired sensors cannot be used.

#### **Key Protection Input**




#### **Key Protection Inputs Specification**

Short-circuit (ON) impedance:  $1 \text{ k}\Omega$  max. Short-circuit (ON) residual voltage: 0.5 VDC max. Current flow for  $0-\Omega$  short-circuit: Approx. 0.5 mA 100 k $\Omega$  min.

Note: Two-wired sensors cannot be used.

### **Voltage Input (PNP Input Mode)**

#### Reset, Count 1, Count 2, Start, and Gate Inputs



#### Reset, Count 1, Count 2, Start, and Gate Inputs Specification


## **Precautions (Common)**

Note: The undermentioned is common for all H7GP/H7HP models.


### **Power Supplies**

When turning the power ON and OFF, input signal reception is possible, unstable, or impossible as shown in the diagram below.

Apply the power supply voltage through a relay or switch in such a way that the voltage reaches a fixed value immediately.



Although the H7GP/H7HP power supply (primary side) is isolated from control circuits (secondary side) by a transformer, the primary and secondary sides of the transformer are linked by a capacitor, making it possible for high-frequency components to leak to the secondary side. Take adequate precautions against electrical shock. Do not connect input circuits to exposed parts (such as the machine body) and be sure that the power supply is turned off before wiring.



### **Self-diagnostic Function**


The following displays will appear if an error occurs.

Display	Error	Correction
	-99999 max. (H7HP, 6-digit model) -9999999 max. (H7HP, 8-digit model)	Press RST Key or reset input
E I	CPU	Press RST Key or turn
E2	Memory	power OFF and then ON

### Flush Mounting

The panel surface is water-resistive (conforming to NEMA 4 and IP66). In order to prevent the internal circuit from water penetration through the space between the counter and operating panel, attach a rubber packing between the counter and operating panel and secure the rubber packing with the Y92F-3 flush-mounting adaptor.

Be sure the rubber packing is installed in the correct direction. The wider portion must be facing the panel when installed, as shown in the following illustration. Using a flat-head screwdriver, press in the Mounting Adapter until it cannot be pressed in any further in order to ensure water-resistive performance.



#### Other

Water resistance may deteriorate depending on the environment. Periodically check water resistance.

Oil resistance is not applicable to all types of oil. Be sure to test any specific oils before actual application.

#### Labels


Unit labels are included with the H7GP/H7HP and DIP switch labels are included with the H7HP. Attach these labels as shown in the following illustrations.

#### **Unit Labels**

H7GP



H7HP



### **DIP Switch Labels**

H7HP




#### **Accessories**

The accessories listed in the following table are included with the H7GP/H7HP. Be sure you understand the use of these accessories and use them correctly.

Name	H7GP	H7HP
Rubber packing	Y92S-32	Y92S-33
Flush mounting adaptor	Y92F-32	Y92F-33

### **Degree of Protection**



### **Protection Against Solid Foreign Objects**

Grade	Protection	Criteria
5	Dust protected (CL)	Limited ingress of dust permitted (no harmful deposit).
6	Dust-tight {[[]]	Totally protected against ingress of dust.

#### **Protection Against Harmful Ingress of Water**

Grade	Protection	Criteria	Examination method
5	Housing jets from all directions	Protected against low-pressure jets of water from all directions; limited ingress permitted.	Spray water from all directions for one minute per m2 of external surface area and for a total time of no less than 3 minutes using the test device shown below.
			Discharging nozzle dia.: 6.3
6	Strong hosing jets from all directions	Protected against strong jets of water, e.g. for use on ship-decks; limited ingress permitted.	Spray water from all directions for one minute per m2 of external surface area and for a total time of no less than 3 minutes using the test device shown below.
			Discharging nozzle dia.: 12.5

### JEM Standards Protection Against Oil

Grade	Protection	Criteria	Criteria
F	Oilproof	eration due to oil drops or spray	No penetration of oil to the extent of interfering with proper operation after dropping the specified cutting oil on a test device for 48 hours at a rate of 0.5 $\ell$ per hour.
G	Oil resistant		No penetration of oil after dropping the specified cutting oil on a test device for 48 hours at a rate of 0.5 $\ell$ per hour.